



# COMPLIANCE TESTED by berkeley analytical

## VOC Emission Test Certificate

**Product Name:** 1/2" PABCO GLASS® INTERIOR - 1/2" PABCO GLASS® INTERIOR

Product Sample Information		Certificate Information	
Company:	PABCO Gypsum	Certificate No:	200611-01
Company Website:	www.pabco gypsum.com	Certified By:	 Raja S. Tannous, Laboratory Director
Product Type:	Wallcoverings	Date:	June 11, 2020
Date Produced:	5/7/2020		

**Reference Standard:** California Department of Public Health CDPH/EHLB/Standard Method Version 1.2, 2017 (Emission testing method for CA Specification 01350)

**Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:**

Exposure Scenario <sup>1</sup>	Individual VOCs of Concern <sup>2</sup>		Formaldehyde <sup>3</sup>		TVOC <sup>4</sup>
	Criterion	Compliant?	Criterion	Compliant?	Range
School Classroom	≤½ Chronic REL	YES	≤9.0 µg/m³	YES	≤ 0.5 mg/m³
Private Office	≤½ Chronic REL	YES	≤9.0 µg/m³	YES	≤ 0.5 mg/m³

**Product Coverage<sup>5</sup>:** Not applicable

1. Exposure scenarios & product quantities for classroom & office are defined in Tables 4-2 – 4-5 (CDPH Std. Mtd. V1.2-2017)
2. Maximum allowable concentrations of individual target VOCs are specified in Table 4-1 (*ibid.*)
3. Maximum allowable formaldehyde concentration is ≤9 µg/m³, effective Jan 1, 2012; previous limit was ≤16.5 µg/m³ (*ibid.*)
4. Informative only; predicted TVOC Range in three categories, i.e., ≤0.5 mg/m³, >0.5 – 4.9 mg/m³, and ≥5.0 mg/m³
5. Informative and applicable only to tests of wet-applied products; grams of sample applied per square meter of substrate

**Standards & Codes Recognizing CDPH Standard Method V1.2 (partial list)**

- USGBC LEED Version 4, BD&C, ID&C
- The WELL Building Standard
- ANSI/GBI 01, Green Building Assessment Protocol
- Green Guide for Healthcare V2.2

**Narrative:** PABCO Gypsum selected a sample representative of its 1/2" PABCO GLASS® INTERIOR - 1/2" PABCO GLASS® INTERIOR gypsum wallboard product and submitted it on 5/19/2020 for testing. Berkeley Analytical measured and evaluated the emissions of VOCs from this sample following CDPH/EHLB/Standard Method V1.2-2017. The results of the test are presented in Berkeley Analytical report, 418-024-01A-Jun1120.

Berkeley Analytical is an independent, third-party laboratory specializing in the analysis of organic chemicals emitted by and contained in building products, finishes, furniture, and consumer products. We are an ISO/IEC 17025 accredited laboratory (IAS, [TL-383](#)); all standards used in performing this test are in Berkeley Analytical's scope of accreditation.

**DISCLAIMER:** THIS CERTIFICATE OF COMPLIANCE AFFIRMS THAT: 1) A SAMPLE OF THE LISTED PRODUCT WAS TESTED ACCORDING TO THE REFERENCED STANDARD; 2) THE MEASURED VOC EMISSIONS FROM THE SAMPLE WERE EVALUATED FOR THE DEFINED EXPOSURE SCENARIO(S); AND 3) THE RESULTS MEET THE ACCEPTANCE CRITERIA OF THE REFERENCED STANDARD(S). BERKELEY ANALYTICAL IS NOT RESPONSIBLE FOR ANY CLAIMS REGARDING A PRODUCT OR PRODUCTS ENTERED INTO COMMERCE THAT MAY BE BASED ON THIS TEST. BERKELEY ANALYTICAL PROVIDES THIS CERTIFICATE OF COMPLIANCE "AS IS" WITHOUT WARRANTY OF ANY KIND, EITHER EXPRESSED OR IMPLIED, INCLUDING BUT NOT LIMITED TO, THE IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR ANY PURPOSE.



P.O. Box 364329  
North Las Vegas, Nevada 89036-8329  
702-643-1016  
FAX 702-643-6249

RE: CDPH VOC Emission Certification for PABCO® Gypsum Family of Products

To Whom It May Concern:

PABCO® Gypsum manufactures all products from naturally occurring calcium sulfate dihydrate ( $\text{CaSO}_4 \cdot 2\text{H}_2\text{O}$ ) to meet or exceed the appropriate ASTM Standard. PABCO® Gypsum's PABCO GLASS® Family of gypsum panel products are manufactured to meet or exceed ASTM C1658 *Standard Specification for Glass Mat Gypsum Panels*, and are specially formulated to provide weather protection and mold- and water-resistance, and are divided into three products, 1/2" PABCO GLASS® Interior, 5/8" PABCO GLASS® Interior Type X, and 1" PABCO GLASS® Shaftliner.

When testing per CHPD for VOC emissions, we sent 1/2" PABCO GLASS® Interior as it is the panel that represents the family, the products have the same core formulations with different thicknesses.

Please allow the VOC Emission Test Certificate issued by Berkeley Analytical for 1/2" PABCO GLASS® Interior to also serve as certification for 5/8" PABCO GLASS® Interior and 1" PABCO GLASS® Shaftliner.

If there is anything further that I can assist with, please do not hesitate to ask.

Thank you.

Deborah Callaway  
Manager, Technical Services  
PABCO® Gypsum  
Desk: 702-407-3753  
Cell: 702-956-2413  
Email: [deborah.callaway@pabco gypsum.com](mailto:deborah.callaway@pabco gypsum.com)  
Website: [www.pabco gypsum.com](http://www.pabco gypsum.com)

This communication and any files or attachments transmitted with it may contain information that is copyrighted or confidential and exempt from disclosure under applicable law. It is intended solely for the use of the individual or the entity to which it is addressed. If you are not the intended recipient, you are hereby notified that any use, dissemination, or copying of this communication is strictly prohibited. If you have received this communication in error, please notify us at once so that we may take the appropriate action and avoid troubling you further. Thank you for your cooperation. Contact information: Pacific Coast Companies, Inc. 1-916-631-6600 and ask for the e-mail administrator.